

	Reading the Mode from an SLC or MicroLogix Controller	Creation Date: 3-22-05
	A113329624	

DISCLAIMER

Because of the variety of uses for this information, the user of and those responsible for applying this information must satisfy themselves as to the acceptability of each application and use of the program. In no event will Allen-Bradley Company be responsible or liable for indirect or consequential damages resulting from the use or application of this information.

The illustrations, charts and examples shown in this application note are intended solely to illustrate the principles of programmable controllers and some of the methods used to apply them. Particularly because of the many variables and requirements associated with any particular installation, Allen-Bradley Company cannot assume responsibility or liability for actual use based upon the illustrations used and applications.

Allen-Bradley Company assumes no patent liability with respect to use of information, circuits, equipment, or software described in this text.

Reproduction of the contents of the application note, in whole or in part, without the express written consent of the Allen-Bradley Company is prohibited.

Software and Firmware Used

All examples shown were developed using V13.03 RSLogix5000.

Document Purpose

This document is not a manual or training material, but an Application Note, which could be useful in helping a Rockwell Automation customer read the mode from an SLC or MicroLogix controller.

Intended Audience

This document is to be used by Rockwell Automation employees/customers supporting and selling Logix based controllers.

Concept of Application Note

Currently, RSLogix 5000 software does allow message instructions to be configured to read from an SLC or MicroLogix status or S2 file. This application note gives you application code to perform this operation.

This makes use of the CIP Generic message. Caution do not change any parameters on the Configuration tab of the message instruction or tags associated with the fields.

The screenshot shows the 'Message Configuration - CIP_Generic_Read' dialog box with the 'Configuration' tab selected. The 'Message Type' is set to 'CIP Generic'. The 'Service Type' is 'Custom'. The 'Source Element' is 'CGR_Request' and the 'Source Length' is 17 Bytes. The 'Service Code' is 4b (Hex), 'Class' is 67 (Hex), 'Destination' is 'CGR_Destination', 'Instance' is 1, and 'Attribute' is 0 (Hex). There is a 'New Tag...' button. At the bottom, there are radio buttons for 'Enable', 'Enable Waiting', 'Start', and 'Done', with 'Done Length: 0'. There are also fields for 'Error Code:', 'Extended Error Code:', and a 'Timed Out' checkbox. At the very bottom are 'OK', 'Cancel', 'Apply', and 'Help' buttons.

Field	Value
Message Type	CIP Generic
Service Type	Custom
Source Element	CGR_Request
Source Length	17 (Bytes)
Service Code	4b (Hex)
Class	67 (Hex)
Destination	CGR_Destination
Instance	1
Attribute	0 (Hex)

You can change the path on the Communication tab. Currently, this is set to read the mode of an SLC 5/05 controller. To communicate to another type of SLC or MicroLogix controller all you will need to do is change the path.

The screenshot shows the 'Message Configuration - CIP_Generic_Read' dialog box with the 'Communication' tab selected. The 'Path' field is set to 'EtherNet, 2, 130.130.130.11'. Below the path, the communication method is set to 'CIP'. The 'Channel' is set to '0', 'Destination Link' is '0', 'Source Link' is '0', and 'Destination Node' is '0' (Octal). The 'Connected' checkbox is unchecked, and 'Cache Connections' is checked. At the bottom, there are radio buttons for 'Enable', 'Enable Waiting', 'Start', and 'Done', with 'Done Length' set to '0'. There are also fields for 'Error Code', 'Extended Error Code', and a 'Timed Out' checkbox. The 'Error Path' and 'Error Text' fields are empty. The 'OK', 'Cancel', 'Apply', and 'Help' buttons are at the bottom right.

Message Configuration - CIP_Generic_Read

Configuration Communication Tag

Path: EtherNet, 2, 130.130.130.11 Browse...

EtherNet, 2, 130.130.130.11

Communication Method

☒ CIP ☐ DH+ Channel: 0 Destination Link: 0

☐ CIP With Source ID Source Link: 0 Destination Node: 0 (Octal)

☐ Connected ☒ Cache Connections

☐ Enable ☐ Enable Waiting ☐ Start ☐ Done Done Length: 0

☐ Error Code: Extended Error Code: ☐ Timed Out

Error Path:

Error Text:

OK Cancel Apply Help

If you will communicating thru the serial port of a Logix controller to and SLC or MicroLogix controller make sure the serial port configurations match. The Logix controllers use BCC error checking and the SLC and MicroLogix use CRC error checking.

The application will return the mode of the controller in the tag Mode[1]. Only the 5 bits that are associated with the mode are put into Mode[1]. The bit definitions can be found below.

S:1/0 to S:1/4	Status	Processor Mode Status/Control
		Bits 0-4 function as follows:
		0 0000 = (0) Remote Download in progress.
		0 0001 = (1) Remote Program mode (the fault mode exists when bit S:1/13 is set along with mode 0 0001)
		0 0011 = (3) Suspend Idle (operation halted by SUS instruction execution) fault mode exists when bit S:1/13 is set along with mode 0 0011.
		0 0110 = (6) Remote Run mode
		0 0111 = (7) Remote Test continuous mode
		0 1000 = (8) Remote Test single scan mode
		0 1001 = (9) Remote Test single step (step until)
	TIP	All modes in the fixed, SLC 5/01, and SLC 5/02 processors are considered as remote because they do not have a keyswitch.
		1 0000 = (16) Download in progress (keyswitch=PROGm)
		1 0001 = (17) PROGm mode - the fault mode exists when bit S:1/13 is set along with mode 1 0001.
		1 1011 = (27) Suspend Idle - the fault mode exists when bit S:1/13 is set along with mode 1 1011 (keyswitch=RUN)
		1 1110 = (30) RUN - the fault mode exists when bit S:1/13 is set along with mode 1 1110 (keyswitch=RUN).
		All other values for bits 0-4 are reserved.